

DECLARATION

Critical Radiant Flux

COSWICK Ltd.

Coswick 3-layer Engineered Hardwood flooring

Critical Radiant Flux

0.35 watts/cm²

corresponding to

Class II rating

Minimum: 0.22 watts/cm²

CODE CLASSIFICATION

2015 Edition of NFPA 101 Life Safety Code, paragraph 10.2.7.4

2015 Edition of NFPA 5000 Building Construction & Safety Code, paragraph 10.2.7.4

2018 Edition of the International Building Code, paragraph 804.2

TEST REPORT

No. 3-40281-0

SGS Govmark

96-D Allen Boulevard, Farmingdale, New York 11735-5626, USA

report № 3-40281-0
and Farmingdale, New York 11735-5626 USA

Vladimir Ianovski, director
Zaslavl, 30 January 2023



Coswick Ltd.
Zaslavl, Republic of Belarus, 223034
t: +375-17-543-20-12
sales@coswick.com

COSWICK Ltd. Y. Kolasa Str. 2B, Zaslavl, Republic of Belarus, 223034
Tel./Fax: +375-17-543-20-12 • E-mail: sales@coswick.com • www.coswick.com