

DECLARATION

Formaldehyde Determination

Coswick Ltd. states that

Coswick 3-layer Engineered Hardwood Flooring Coswick 3-layer Mosaic Flooring

is

less than 0.008 ppm
(below limit of quantitation)

corresponding to

ULEF
0.05 ppm — CARB Phase 2

NAUF — No Added Urea-Formaldehyde

We do not add any formaldehyde in the production of our products (NAUF).
The only formaldehyde content is natural for wood materials.

TEST REPORTS

FSC3821R and FSC3822R

Capital Testing and Certification Services
42777 Trade West Drive, Sterling, VA 20166, USA

Vladimir Ianovski, director
Zaslavl, 30 January 2023

№ FSC3821R, FSC3822R
42777 Trade West Drive, Sterling, VA 20166, L



Coswick Ltd.
Zaslavl, Republic of Belarus, 223034

COSWICK Ltd.
Y. Kolasa Str. 2B, Zaslavl, Republic of Belarus, 223034
Tel./Fax: +375-17-543-20-12 • E-mail: sales@coswick.com
www.coswick.com